STABILITY REPORT

APN VIDHYASHRAM

Address :-

Valliammai street,Sri Moogambigai Nagar,
Venpakkam,Varanvasi-631604
Kanchipuram District.

Period :- from 01-06-2024 to 31-05-2027 (Three years)

Reported By:-

V.EZHILARASAN, ME,M.S(Valu).,
Govt. approved Valuer,Chartered Engineer
Panel Engineer-Class-IA,
Registered Engineer in CMDA,GCC ,DTCP
and Competent person for Industrial Safety and Health
Issuing Stability certificates for Factories.
EZHIL ENTERPRISES
Flat No.14/3, First Floor, Welcome Colony,
Ambattur Estate Road,Anna Nagar West Ext.,
Chennai-600 101. Mobile No.9444017383
Mail:-ezhilenterprises@gmail.com

V. EZHILARASAN, M.E., M.S. (Val.)
Govt. Approved Valuer, Chartered Engineer
Panel Engineer Class - IA, Chennai, Chengalpattu & Thiruvallur Districts, Registered Engineer CMDA, GCC and DTCP and Competent Person
for issuing Stability Certificate for factories

EZHIL ENTERPRISES
ENGINEER & BUILDERS
Flat No. 14/3, First Floor, Welcome Colony,
Ambattur Estate Road, Anna Nagar West Extn.,
Chennai - 600 101.
Mobile : 94440 17383, 99400 77077, 94990 33588
E-mail : ezhilenterprises@gmail.com
Web : www.ezhilenterprises.com

■ CHARTERED ENGINEER ■ GOVT. APPROVED VALUER ■ PANEL ENGINEER CLASS - IA ■ REGISTERED ENGINEER GRADE - I
■ REGISTERED STRUCTURAL ENGINEER GRADE - I ■ STABILITY CERTIFICATES ■ APPROVAL DRAWINGS ■ BUILDING PLAN ■ ELEVATION ■ VALUATION

ANNEXURE TO STATEMENT ACCOMPANYING FORM – 'A'

I have inspected the Premises building for APN VIDHYASHRAM Valliammai street, Sri Moogambigai Nagar, Venpakkam, Varanavasi, Kanchipuram District - 631 604. Building inspected with School Representative.

This Report covers only the Building mentioned in the form A, B, C and E and does not include any other Buildings / Blocks or Structures either in Existing Building or building in the same premises.

I hereby advise that the periodical Repairs and Renovations shall be carried out to the Entire Building Block regularly. Further Necessary firefighting equipment's should be kept in the premises and should be trained for operation. No structures with inflammable roof must be allowed within the premises, if any fire accident / Mishap occur we are not held responsible. Emergency exit to be provided as per norms.

Structural Alteration/Deviation should not be carried out to any of the blocks for Whole Building or any Part of Building without prior permission from the Competent Authority. All Electrical points, wiring Gadgets has to be checked properly and to be maintained regularly. Periodic water proofing treatment is to be done as per standards.

This Report does not cover any Structure raised after issuance of this certificate during the period of this certificate. Further additional construction either in G.F or in any other Floors / Blocks the necessary approvals / structural design / stability has to be obtained prior or subsequently as the case may be.

All Electrical Panel Boards / Main Switches / cables/ Generator/ Electrical Maintenance Room have to be kept as per standard Norms. Access to open terraces to be restrained other than periodical maintenance and Inspection.

The UG sump, Manholes OHT, Inspection Chamber or other Openings has to be Sealed with cover slab and properly cleaned and disinfected periodically as per standard norms and properly documented.

If any above mentioned aspects were found violated at a later date after issue of this Report followed with issuance of License by competent authority we are not held responsible, the moment deviation or violation happened after issuance of this report, this Report gets cancelled automatically. Legal aspects were not considered in this report.

Place: Chennai-101
Date: 27-05-2024

Signature of Engineer
V. EZHILARASAN, ME,M.S.(Valu)
Govt. Approved Valuer, Chartered Engineer
Panel Engineer Class-1A Chengalpattu District
Flat No.14/3, First Floor, Welcome Colony,
Ambattur Estate Road, Anna Nagar West Ext.,
Chennai-600 101. Cell : 9444017383
E-mail : ezhilenterprises@gmail.com

STATEMENT ACCOMPANYING FORM-A

1.	Door Number of the building.	:	APN VIDHYASHRAM
2.	Location (Street No. Ward No. Name of the place Corporation/ Municipality / Panchayat Union / Township /Cantonment.	:	valliammai street,Sri Moogambigai Nagar, Venpakkam, Varanavasi, kanchipuram District - 631 604
	(a)Survey /Village	:	Survey No.47/1A,1B,53/1A of Periyamadurapakkm Villag
	(B)Local body	:	
3.	Year of Constructions	:	GF-2004 and GF & FF- 2008, and FF & SF-2010
4.	Approximate cost of construction	:	Rs.60.00 Lakhs
5.	Purpose for which building is being used or proposed to be used	:	Educational purpose
6.	Purpose for which the building has hither to been used.	:	Educational School-CBSE
7.	Details of construction of the building particulars of the foundation, soil specification of the various parts as under	:	RCC Framed structure
(a)	Foundation	:	RCC footing and Column & Isolated Footing
(b)	Basement	:	RCC Column, Plinth Beam & Brick in CM
(c)	Superstructure (are to be given)	:	RCC Column & ACC Blocks in CM
(d)	Floor and Roof (are to be given)		Flooring : Vitrified Tiles Roof: RCC Slab
8.	Period for which the license is required	:	01-06-2024 to 31-05-2027 (Three years)
9.	Number of the persons to be accommodate	:	1100 Pupils (one Thousand pupils Only)

Signature of the School Correspondent

APN VIDHYASHRAM
Valliammal Street, Sri Moogambigai Nagar,
VENPAKKAM, VARANAVASI-631604.
Kancheepuram District.

Signature of the Engineer

V. EZHILARASAN, ME,M.S.(Valu)
Govt. Approved Valuer, Chartered Engineer
Panel Engineer Class-1A Chengalpattu District
Flat No.14/3, First Floor, Welcome Colony,
Ambattur Estate Road, Anna Nagar West Ext.,
Chennai-600 101. Cell : 9444017383
E-mail : ezhilenterprises@gmail.com

FORM – B

STATEMENT OF ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDESS

Location of the Building Door No. Street Name & name of the place	Age of the building	Value of the building	No. of story's	Shorts description of structure RCC framed, or load bearing masonry
(1)	(2)	(3)	(4)	(5)
APN VIDHYASHRAM valliammai street, Sri Moogambigai Nagar,Venpakkam, Varanavasi, kanchipuram District - 631 604	GF-2004 and GF & FF-2008, and FF & SF-2010	Rs.60 Lakhs	GF +2 Floors Only	RCC Framed structure Flooring with vitrified tiles and cement mortar.

Purpose for which the building its certified for use	The period for which the building will be structurally sound	No. of persons to be accommodated	Remarks
(6)	(7)	(8)	(9)
Educational School(CBSE)	01-06-2024 to 31-05-2027 (Three Years)	1100 Pupils	Building Structurally sound.

Signature of the School Correspondent

APN VIDHYASHRAM
Valliammai Street, Sri Moogambigai Nagar,
VENPAKKAM, VARANAVASI-631604.
Kancheepuram District.

Signature of the Engineer

V. EZHILARASAN, ME,M.S.(Valu)
Govt. Approved Valuer, Chartered Engineer
Panel Engineer Class-1A Chengalpattu District
Flat No.14/3, First Floor, Welcome Colony,
Ambattur Estate Road, Anna Nagar West Ext.,
Chennai-600 101 Cell 9444017383
E-mail : ezhilenterprises@gmail.com

FORM – C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNES UNDER SUB-SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING) ACT 1965 (TAMILNADU ACT 13 OF 1965) REFERRED TO IN RULE 4 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) RULES 1966.

I certify that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1.	Foundation	:	RCC Footing
(I)	Depth below ground level	:	8ft from Ground Level
(ii)	Nature of the soil out in the foundation level	:	Hard Soil
(iii)	Pressure at foundation	:	92 KN/M²
(iv)	Probable safe bearing capacity of the strata met with at foundation.	:	200 KN/M²
2.	Superstructure	:	
(I)	Maximum stress in the most critical section of the masonry and concrete	:	MASONRY :- N/MM² RCC Column :- N/MM²
(ii)	Nature of masonry and concrete and its safe permissible stress	:	MASONRY :- 5.10 N/MM² RCC Column :- 25.00 N/MM²

The structural soundness of the building has been verified by me with reference to IS loading standards 895 (latest version) and other relevant Indian Standard Code of practices and I declare that the building is structurally sound to be used as School building (educational) for the purpose noted in the statement. A license may be granted for a period from 01-06-2024 to 31-05-2027 (Three years) inclusive.

CERTFIED that no thatched buildings are used for conducting any classes for school premises. If any thatched buildings are constructed after the issue of certificate, ENGINEER is not held responsible for any fire accident that occurs later that I/We aware that your LICENSE will be cancelled.

Signature of the School Correspondent

APN VIDHYASHRAM
Valliammai Street, Sri Moogambigai Nagar,
VENPAKKAM, VARANAVASI-631604.
Kancheepuram District.

Signature of the Engineer

V. EZHILARASAN, ME,M.S.(Valu)
Govt. Approved Valuer, Chartered Engineer
Panel Engineer Class-1A Chengalpattu District
Flat No.14/3, First Floor, Welcome Colony,
Ambattur Estate Road, Anna Nagar West Ext.,
Chennai-600 101. Cell 9444017383
E-mail : ezhilenterprises@gmail.com

FORM E

Form of report to be made to the competent authority by inspecting authorities or officers appointed under other act under section 25 of the (Madras Public Buildings)Act 1965 (MADRAS Act 13 of 1965) referred to in Rule 7 of the madras Public Buildings Licensing rule 1966.

1.	Name and Designation of inspecting Authority or officer appointed or having jurisdiction under any other Act or law	:	V.EZHILARASAN, ME,MS(Valu) Govt Approved Valuer & Chartered Engineer, Panel Engineer Class–1A, Chennai, Chengalpattu and Thiruvallur Districts. Flat No.14/3, First Floor,Ambattur Estate Road, Anna Nagar West Extn, Chennai -600 101.
2.	Location of the building inspected Door No. Street No., Name of the place/ie Municipal Corporation, Municipality/ panchayat/ Panchayat Union/Town ship/ Cantonment.	:	APN VIDHYASHRAM valliammai street, Sri Moogambigai Nagar, Venpakkam,Varanavasi, kanchipuram District - 631 604
3.	Date of Inspection	:	27-05-2024
4.	Purpose for which the Building is used	:	Educational School-CBSE
5.	Nature of Defects Noticed	:	Nil (Maintained Properly)
6.	Suggestion for rectifying defects	:	Nil
7.	If in dangerous condition immediate action recommended be taken	:	Necessary safety to be followed.

V. EZHILARASAN, ME,M.S.(Valu)
Govt. Approved Valuer, Chartered Engineer
Panel Engineer Class-1A Chengalpattu District
Flat No.14/3, First Floor, Welcome Colony,
Ambattur Estate Road, Anna Nagar West Ext.,
Chennai-600 101. Cell 9444017383
E-mail ezhilenterprises@gmail.com

From
The District Collector,
Kancheepuram District,
Kancheepuram.

To
The District Collector,
Chennai District,
Singaravelar Maaligai, 68, Rajaji Salai,
Chennai. 600 001

Rc. No. 21465 / 2019 / M1 Dated 18.10.2019.

Sir,

Sub: Tamil Nadu Public Building (Licensing) Act 1965 and rules 1966 – Kancheepuram District – Inclusion of the name of Thiru V. Ezhilarasan in the panel of private practicing Engineer under Class IA in Kancheepuram District - requested - regarding.

Ref: 1) Representation from Thiru V. Ezhilarasan, Ezhil Enterprises, No. 19 & 20, TNHB Shopping Complex, Thirumangalam, Anna Nagar West Extn., Chennai 600 101 Dated 1.7.2019.
2) District Collector, Chennai Proceedings No. V2/27806/14 Dated 12.4.2017.

****

I invite kind attention to the references cited.

In the reference 1st cited, one Thiru V. Ezhilarasan, residing at No. 19 & 20. TNHB Shopping Complex, Thirumangalam, Anna Nagar West Extn., Chennai 600 101 has sent a representation stating that his name had been included in the panel of Private Practicing Engineer in Chennai District. He has requested to include his name in the panel of Private Practicing Engineer under Class IA in Kancheepuram District.

Hence, I request you to send your concurrence for inclusion of Thiru V. Ezhilarasan in the panel of Private Practicing Engineer in Kancheepuram District.

Yours faithfully,
Sd./- M. Narayanan,
for District Collector,
Kancheepuram.

V. EZHILARASAN, ME.M.S.(Valu)
Govt. Approved Valuer, Chartered Engineer
Panel Engineer Class-1A Chengalpattu Dist./Trv
Flat No.14/3, First Floor, Welcome Colony,
Ambattur Estate Road, Anna Nagar West Ext.,
Chennai-600 101. Cell 9444017383
E-mail : ezhilenterprises@gmail.com

By order/

Huzur Sarishtadar (M)

Copy to Thiru V. Ezhilarasan, Ezhil Enterprises, No. 19 & 20, TNHB Shopping Complex, Thirumangalam, Anna Nagar West Extn., Chennai 600 101

வாலாஜாபாத் வட்டாட்சியர் அவர்களின் செயல்முறைகள்
முன்னிலை திரு.கோ.கருணாகரன், எம்.காம்.,

மூ.மு.1154/2024/அ1 நாள்.16.07.2024

பொருள் கட்டிட உரிம சான்று - பெயர் மாற்றம் - காஞ்சிபுரம் மாவட்டம் - வாலாஜாபாத் வட்டம் - தென்னேரி குறுவட்டம் - நெ.63,பெரியமதுரப்பாக்கம் கிராமத்தில் இயங்கி வரும் A.P.N Matriculation Hr.Sec School கட்டிட உரிமத்தில் பெயர் மாற்றி வழங்க கோரி அதன் தாளாலர் மனு அளித்தது - கட்டிட உரிமம் வழங்கி உத்தரவிடுதல் - தொடர்பாக

பார்வை தென்னேரி வருவாய் ஆய்வாளர் அறிக்கை உமு.155/2024/அ1 நாள்.28.06.2024

உத்தரவு.

காஞ்சிபுரம் மாவட்டம், வாலாஜாபாத் வட்டம், பெரிய மதுரப்பாக்கம் கிராமம் என்ற முகவரியில் இயங்கி வரும் A.P.N Matriculation School ஆனது தற்போது **A.P.N Vidhyashram** என பெயர் மாற்றம் செய்யப்பட்டுள்ளதால் மேற்படி பள்ளிக்கு ஏற்கனவே வழங்கப்பட்ட கட்டிட உரிமச் சான்றினை (மூ.மு.862/2022/அ1 நாள்.13.06.2022) ரத்து செய்தும், தற்போது 01.06.2024 முதல் 31.05.2027 வரை மூன்று ஆண்டுகளுக்கு கட்டிட உரிமம் புதுப்பிக்க புதிய கட்டிட உரிமம் வழங்கியும் உத்தரவிடப்படுகிறது.

இணைப்பு. Form-D Certificate

16/07/24
வட்டாட்சியர்,
வாலாஜாபாத்.

பெறுநர்
The Correspondent,
A.P.N Vidhyashram
Periya Madurapakkam Village
Walajabad Taluk,
Kanchipuram District.

16/07/24

Dis. 1154/2024/A1
Date.16 .07.2024

Taluk Office,
Walajabad.

FORM D

Form of License under Sub-Section (i) of section 6 of the Tamil Nadu Public Building (licensing) Act 1965. Tamil Nadu Act 13 of 1965 reference to rule 6 of the Tamil Nadu Building (license) Act 1986.

LICENSE

License No. 09/2024

License Fee Rs. 1000/-
Dated: 16/05/2022
SBI, Walajabad

License is here by granted to, The Correspondent of A.P.N Vidhyashram CBSE School ,Located at Periyamadhurapakkam Village, Walajabad Taluk, Kanchipuram District. Tamil Nadu, for the purpose of running a CBSE School in the building specified in the statement furnished below and subject to the conditions and the period mentioned here under.

The Period of validity of the license shall be for from 01/06/2024 to 31/05/2027

Tahsildar, 16/07/24.
Walajabad.

16/07/24

Statement to Accompany the License

Location of the Building Door No. Street and the Name of the Place and Survey No.	Purpose for which the building in the license to be used as public building	No. of persons to be accommodated.
The Correspondent, A.P.N Vidhyashram Periya Madurapakkam Village Walajabad Taluk, Kanchipuram District. S.No.47/1A, 47/1B &53/1A	A.P.N Vidhyashram	1100 Pupils (One Thousand One hundred Students only)

Tahsildar, 16/07/24.
Walajabad.

To
The Correspondent,
A.P.N Vidhyashram
Periya Madurapakkam Village
Walajabad Taluk,
Kanchipuram District.

16/07/24